

TAMIL NADU GENERATION AND DISTRIBUTION CORPORATION LTD.
Technical Branch

...

From
Er.U.S.Pongiannan, B.E.,
Chief Engineer/Commercial,
144, Anna Salai,
Chennai-600 002.

To
All the Chief Engineers/Distribution Regions.

Lr.No.CE/Comml/SE/Comml/EE3/AEE2/F.ELCB/D.348/19 dt.18.09.2019.

Sub:- Electricity – Installation of ELCB by the applicant of the new service connection in their premises as per the Central Electricity Authority (Measures relating to safety and electric supply) Regulations, 2010 – Regarding.

Ref:- Memo No.CE/Comml/SE/Comml/EE3/AEE2/F.ELCB/D-91/2019, dt.13-03-2019

Kind attention is invited to the above cited reference, wherein instruction was issued to effect electricity service connections to every electrical installation other than the voltage not exceeding 250 V, below 2 kW with installation of earth leakage protective device.

In the Distribution Review Meeting held on 18-09-2019, the Director (Distribution) has instructed all the Chief Engineers of the Distribution Regions to adhere the above instruction strictly and not to effect new electricity service connections (other than the voltage not exceeding 250 V, below 2 kW load) without earth leakage protective device installed by the applicants in their premises. The instruction already issued is enclosed herewith for reference.

Encl:- As above

Sd/- dated 18-09-2019
Chief Engineer/Commercial

Copy to all the Superintending Engineers/EDCs.

Copy to the Executive Assistant to Director (Distribution) for information.